

Listado de equipamiento

6. Quotes


Section	Model Name	Qty	Note	Unit Cost	Amount
Outdoor Unit	AM200FXVAGH/EU		1DVM S(NEW) (Heat Pump)	0	0
	AM220FXVAGH/EU		1DVM S(NEW) (Heat Pump)	0	0
Indoor Unit	AM022FNQDEH/EU	3	NEO FORTE	0	0
	AM280FNHDEH/EU	4	HSP DUCT	0	0
Piping	MXJ–YA4119M		1the first refnet joint	0	0
	MXJ–YA1509M	2	refnet joint	0	0
	MXJ–YA2512M		1refnet joint	0	0
	MXJ–YA2815M		1refnet joint	0	0
	MXJ–YA3419M		1refnet joint	0	0
	MXJ–TA3819M		1outdoor joint	0	0
Optional Accessories		0		0	0
Control System		0		0	0
Ref. Pipe	1/2"	16.78	m	0	0
	1 1/8"	15.13	m	0	0
	1 3/8"	3.55	m	0	0
	1 5/8"	2.16	m	0	0
	1/4"	8.77	m	0	0
	3/4"	5.71	m	0	0
	3/8"	33.37	m	0	0
	5/8"	14.41	m	0	0
Drain Pipe	7/8"	26.08	m	0	0
				0	0
Additional Ref. Quantity	R410A	12.030	kg	0	0
합계					

Standard					
Section	Model Name	Qty	Note	Unit Cost	Amount
Optional Accessories		0		0	0
Control System		0		0	0
합계					

- * The power supply cable is selected according to the condition of air cluvert installation / ambient temperature 30℃ / single multi conductor cables. If the condition is different from those above consult the installation expert.
- * The electronic capacity of building is selected according to [–10℃/–15℃/Max of Power Input].
- * The power should be supplied through the breaker(MCCB & ELB).
- * Install the Air filter or Suction diffuser when duct type ID is installed.
- * Install the horizontal drainpipe with a slope of 1/100 or more.
- * Install the air vent in the horizontal drainpipe to prevent water flow back to the indoor unit.
- * Install U–trap at the end of the drainpipe to prevent a nasty smell to reach the indoor unit. If natural drain is not supported, the drain pump be installed.
- * Distance between ID and Beam projector : More than 2m
- * Distance between ID and Fire detector : More than 1.5m

Universidad de Buenos Aires

SUBSECRETARÍA DE INFRAESTRUCTURA



Universidad de Buenos Aires

30 ANIVERSARIO

Facultad de Psicología

Facultad de Psicología

Instalación Termomecánica

Plano de Cañerías

Edificio: Urquiza 752 C.A.B.A.

Listado de Equipamiento

Fecha: Septiembre 2015

Nº de Plano:

IT - nº 12